

Milbank	UPC	Cooper B-Line	Service	Service Type	# of Terminals	Position (Vrt)/ Gang (Hrz)	Bypass	Hub Closing Plate	Knock Out Layout	5th Jaw Included	5th Jaw Kit	Bypass Link	Clear Closing Plate
RINGLESS NON-LEVER BYPASS 600 VOLT, SELF CONTAINED, SINGLE METER SOCKETS													
125 AMP CONTINUOUS													
U7487-YL-TG	78205131419	EN12L41GRST	OH	10/3W	4	-	NO	NO	Fig 1	NO	50365	SJ-100	25162
U7487-RL-TG	78205131439	EN12L43GRST	OH/UG	10/3W	4	-	NO	YES (AW CAP)	Fig 2	NO	50365	SJ-100	25162
200 AMP CONTINUOUS													
U7021-RL-TG	78205131451	EN20L41GRST	OH	10/3W	4	-	NO	NO	Fig 3	NO	50365	SJ-100	25162
U7040-O-TG	78205131466	EN20L42GRST	UG	10/3W	4	-	NO	NO	Fig 4	NO	50365	SJ-100	25162
U7040-XL-TG	78205131487	EN20L43GRST	OH/UG	10/3W	4	-	NO	YES (AW CAP)	Fig 5	NO	50365	SJ-100	25162
U1980-0	78205132561	EN20L44GRST	UG Bussed Offset	10/3W	4	-	NO	YES (AW CAP)	Fig 6	NO	50365	SJ-100	25162
RINGLESS NON-LEVER BYPASS SELF CONTAINED, METER MAINS													
125 AMP MAXIMUM													
U3499-XL-100	78205138508	ENCB10L24A3GRST	OH/UG	10/3W	4	-	NO	YES (AW CAP)	Fig 7	NO	50365	SJ-100	25162
150 AMP MAXIMUM													
U3990-XL-150	78205138509	ENCB15L24A3GRST	OH/UG	10/3W	4	-	NO	YES (AW CAP)	Fig 8	NO	50365	SJ-100	25162
200 AMP MAXIMUM													
U3990-XL-200	78205138510	ENCB20L24A3GRST	OH/UG	10/3W	4	-	NO	YES (AW CAP)	Fig 8	NO	50365	SJ-100	25162
RINGLESS LEVER BYPASS SELF CONTAINED, SINGLE METER SOCKETS													
125 AMP CONTINUOUS													
U2272-RL-5T9	78205138492	EC12L41GR1N	OH	10/3W	4	-	NJCLB-1	NO	Fig 1	YES-2	-	-	25162
U7573-RL	78205138491	EC12L71GRST	OH	30/4W	7	-	NJCLB-1	NO	Fig 2	-	-	-	25162
200 AMP CONTINUOUS													
U9800-RRL-QG-BL	78205138480	EL20L41GR1N	OH	10/3W	4	-	YES	NO	Fig 1	YES-2	-	-	25162
U9801-RXL-QG	78205138490	EL20L43GRST	OH/UG	10/3W	4	-	YES	YES	Fig 3	NO	50366	-	25162
U4721-O-BL	78205138479	EL20L45GR1N	OH/UG Non-Bussed Offset	10/3W 10/3W or 30/3W	4	-	YES	YES (AW CAP)	Fig 4	YES-2	-	-	25162
U9318-RL	78205132601	EL20L51GRST	OH	10/3E or 30/3W	5	-	YES	NO	Fig 2	YES-3	-	-	25162
U9319-XL-QG	78205132605	EL20L53GRST	OH/UG	10/3E or 30/3W	5	-	YES	YES (AW CAP)	Fig 3	YES-3	-	-	25162
U9700-RRL-QG-BL	78205138483	EL20L71GR1N	OH	30/4W	7	-	YES	NO	Fig 1	-	-	-	25162
U7421-RXL	78205138487	EL20L71GRST	OH	30/4W	7	-	YES	NO	Fig 2	-	-	-	25162
U9701-RXL-QG	78205138488	EL20L73GRST	OH/UG	30/4W	7	-	YES	YES (AW CAP)	Fig 3	-	-	-	25162
U4910-O-BL	78205138482	EL20L75GR1N	OH/UG Non-Bussed Offset	30/4W	7	-	YES	YES (AW CAP)	Fig 4	-	-	-	25162
320 Amp Continuous													
U2124-X	78205140883	EL32T44GRST	UG Bussed Offset	10/3W	4	-	YES	NO	Fig 5	NO	50366	-	25162
U4778-X-BL	78205138481	EL32T45GR1N	OH/UG Non-Bussed Offset	10/3W	4	-	YES	YES (AW CAP)	Fig 6	NO	50366	-	25162
U2448-X	78205138485	EL32T46GRST	OH/UG Bussed Offset	10/3W	4	-	YES	YES (AW CAP)	Fig 7	NO	50366	-	25162
U4911-X-BL	78205138484	EL32T75GR1N	OH/UG Non-Bussed Offset	10/3W	7	-	YES	YES (AW CAP)	Fig 6	-	-	-	25162
U2594-X	78205138486	EL32T76GRST	OH/UG Bussed Offset	30/4W	7	-	YES	YES (AW CAP)	Fig 8	-	-	-	25162
NJCLB-1 Bypass lever operates bypass only, non jaw clamping													
YES-2 Includes 5th jaw installed at 9 o'clock. May be relocated to 6 o'clock.													
YES-3 Includes 5th jaw installed at 6 o'clock. May be relocated to 9 o'clock													
RINGLESS, LEVER BYPASS SELF-CONTAINED, METER MAINS													
100 AMP MAXIMUM													
U3741-XL-100-BL	78205138497	ECCB10L24A3GR1N	OH/UG	10/3W	4	-	NJCLB	YES (AW CAP)	Fig 9	NO	50366	-	25162
U3771-XL-100-BL	78205138498	ECCB10L27A3GRST	OH/UG	30/4W	7	-	NJCLB	YES (AW CAP)	Fig 10	-	-	-	25162
200 AMP-MAXIMUM													
U3791N-RXL-200-BL	78205138500	ELCB20L24A5GR1N	OH/UG Non-Bussed Offset	10/3W	4	-	YES	YES (AW CAP)	Fig 11	NO	50366	-	25162
U3781N-RXL-200-BL	78205138499	ELCB20L27A5GR1N	OH/UG Non-Bussed Offset	30/4W	7	-	YES	YES (AW CAP)	Fig 11	-	-	-	25162
320 AMP - CONTINUOUS													
U4031-O-2/200	78205138501	ELCB32C24A4GRST	UG Bussed Offset	10/3W	4	-	YES	NO	FIG 12	NO	50366	-	25162
U3791N-RXL-200-BL	78205138502	ELCB32C24A5GR1N	OH/UG Non-Bussed Offset	10/3W	4	-	YES	YES (AW CAP)	Fig 13	NO	50366	-	25162
RINGLESS METERING VERTICAL METER SOCKETS													
Lever Bypass 200 Amp --Condo Pak with Main Breaker Provisions (5th Jaw Installed in 9 O'clock Position) Jaw May Be Relocated to 6 O'Clock													
U4372-XT-5T9	78205141433	VELMP20432LGRST5K9	OH/UG	10/3W	4	2	YES	Yes	Fig 8	YES	-	-	25162
U4373-XT-5T9	78205141434	VELMP20433LGRST5K9	OH/UG	10/3W	4	3	YES	Yes	Fig 9	YES	-	-	25162
U4374-XT-5T9	78205141435	VELMP20434CGRST5K9	OH/UG	10/3W	4	4	YES	Yes	Fig 10	YES	-	-	25162
U4375-XT-5T9	78205141436	VELMP20435CGRST5K9	OH/UG	10/3W	4	5	YES	Yes	Fig 11	YES	-	-	25162
U4376-XT-5T9	78205141546	VELMP20436CGRST5K9	OH/UG	10/3W	4	6	YES	Yes	Fig 12	YES	-	-	25162
Non Lever Bypass (1) 100 Amp Continuous													
U2692-XL	78205141426	VEN10432CGRST	OH/UG	10/3W	4	2	NO	Yes	Fig 1	No	50365	SJ-100	25162
U2693-XL	78205141544	VEN10433CGRST	OH/UG	10/3W	4	3	NO	Yes	Fig 2	No	50365	SJ-100	25162
Owner's Loop 200 Amp Continuous (Top Socket) / 125 Amp Continuous (Bottom Socket) Owner's meter socket (far right side) is lever bypass, all other positions are non-lever bypass													
U2264-XL	78205141437	VEN21432CGRSTOL	OH/OG	10/3W	4	2	NJCLB-1	Yes	Fig 1	NO	50365	SJ-100	25162
Non Lever Bypass 125 Amp - Condo Pak with Main Meter Breaker Provisions													
U2852-X	78205141427	VENMP12432LGRST	OH/UG	10/3W	4	2	NO	Yes	Fig 3	NO	50365	SJ-100	25162
U2853-X	78205141428	VENMP12433LGR1N	OH/UG	10/3W	4	3	NO	Yes	Fig 4	NO	50365	SJ-100	25162
U2854-X	78205141429	VENMP12434CGRST	OH/UG	10/3W	4	4	NO	Yes	Fig 5	NO	50365	SJ-100	25162
U2855-X	78205141430	VENMP12435CGRST	OH/UG	10/3W	4	5	NO	Yes	Fig 6	NO	50365	SJ-100	25162
U2856-X	78205141630	VENMP12436CGRST	OH/UG	10/3W	4	6	NO	Yes	Fig 7	NO	50365	SJ-100	25162
Non Lever Bypass 200 Amp - Condo Pak with Main Breaker Provisions													
U2862-X	78205141431	VENMP20432LGRST	OH/UG	10/3W	4	2	NO	Yes	Fig 3	NO	50365	SJ-100	25162
U2863-X	78205141432	VENMP20433LGRST	OH/UG	10/3W	4	3	NO	Yes	Fig 4	NO	50365	SJ-100	25162
U2864-X	78205141631	VENMP20434CGRST	OH/UG	10/3W	4	4	NO	Yes	Fig 5	NO	50365	SJ-100	25162
U2865-X	78205141632	VENMP20435CGRST	OH/UG	10/3W	4	5	NO	Yes	Fig 6	NO	50365	SJ-100	25162
U2866-X	78205141633	VENMP20436CGRST	OH/UG	10/3W	4	6	NO	Yes	Fig 7	NO	50365	SJ-100	25162
NJCLB-1 Bypass lever operates bypass only, non jaw clamping													

Milbank	UPC	Cooper B-Line	Service	Service Type	# of Terminals	Position (Vrt)/ Gang (Hrz)	Bypass	Hub Closing Plate	Knock Out Layout	5th Jaw Included	5th Jaw Kit	Bypass Link	Clear Closing Plate
RINGLESS METERING HORIZONTAL METER GANG SOCKETS													
Non Lever Bypass - 100 Amp Continuous Per Position, Left Feed													
U7362-DL	78205140876	HEN10412GRST	OH	10/3W	4	2	NO	NO	Fig 1	NO	50365	SJ-100	25162
U7363-DL	78205140877	HEN10413LGRST	OH	10/3W	4	3	NO	NO	Fig 2	NO	50365	SJ-100	25162
U8212-XL	78205140878	HEN10432LGRST	OH/UG	10/3W	4	2	NO	YES	Fig 3	NO	50365	SJ-100	25162
U8213-XL	78205140879	HEN10433LGRST	OH/UG	10/3W	4	3	NO	YES	Fig 4	NO	50365	SJ-100	25162
U8214-XL	78205140881	HEN10434LGRST	OH/UG	10/3W	4	4	NO	YES	Fig 5	NO	50365	SJ-100	25162
Non Lever Bypass - 200 Amp Continuous Per Position, Center Feed													
U1252-X-K1	78205140882	HEN20432CGRST	OH/UG	10/3W	4		NO	YES	Fig 6	NO	50365	SJ-100	25162
Owner's Loop (Owner's meter socket (far right side location) is lever bypass, all other positions are non-lever bypass) - 125 Amp Continuous Per Position, Center Feed													
U3763-XL	78205139782	HEN12433CGRSTOL	OH/UG	10/3W	4	3	NJCLB-1 owner's meter only	YES	Fig 10	NO	50365	SJ-100	25162
U3764-XL	78205139783	HEN12434CGRSTOL	OH/UG	10/3W	4	4	NJCLB-1 owner's meter only	YES	Fig 11	NO	50365	SJ-100	25162
U3765-XL	78205139784	HEN12435CGRSTOL	OH/UG	10/3W	4	5	NJCLB-1 owner's meter only	YES	Fig 12	NO	50365	SJ-100	25162
Non Lever Bypass - 200 Amp (left Hand Socket) / 125 Amp (Right Hand Socket) Continuous, Left Feed													
U2602-XL	78205139786	HEN21432LGRST	OH/UG	10/3W	4	2	YES	YES	Fig 3	NO	50365	SJ-100	25162
Non-Jaw Clamping Lever Bypass - 100 Amp Continuous Per Position, Center Feed													
	78205140869	HEC10432CGR1N	OH/UG	10/3W	4	2	NJCLB-1	YES	Fig 13	YES-2	-	SJ-100	25162
	78205140874	HEC10433CGR1N	OH/UG	10/3W	4	3	NJCLB-1	YES	Fig 14	YES-2	-	SJ-100	25162
	78205140875	HEC10434CGR1N	OH/UG	10/3W	4	4	NJCLB-1	YES	Fig 15	YES-2	-	SJ-100	25162
Lever Bypass - 200 Amp Continuous Per Position, Center Feed													
U2872-XI-5T9	78205139772	HEL20432CGR1N	OH/UG	10/3W	4	2	YES	YES	Fig 7	YES-2	-	SJ-100	25162
U2873-XI-5T9	78205139774	HEL20433CGR1N	OH/UG	10/3W	4	3	YES	YES	Fig 8	YES-2	-	SJ-100	25162
U2874-XI-5T9	78205139775	HEL20434CGR1N	OH/UG	10/3W	4	4	YES	YES	Fig 9	YES-2	-	SJ-100	25162
U2732-XI	78205140301	HEL20732CGR1N	OH/UG	30/4W	7	2	YES	YES	Fig 7	-	-	SJ-100	25162
NJCLB-1 Bypass lever operates bypass only, non jaw clamping													
YES-2 Includes 5th jaw installed at 9 o'clock. May be relocated to 6 o'clock.													